



**LUSAKA CITY COUNCIL  
ENGINEERING SERVICES DEPARTMENT  
LUSAKA FIRE BRIGADE**

CENTRAL FIRE STATION  
CHURCH ROAD  
FAIRVIEW  
TELEPHONE 228265  
VERBAL ENQUIRIES TO:  
MR. G. MUKUPA

P.O. BOX 32734  
LUSAKA  
REPUBLIC OF ZAMBIA

SUB FIRE STATION  
UMUZILIKAZI ROAD  
HEAVY INDUSTRIAL AREA  
TELEPHONE 240231

ESD/FB/95/GM/ism

21<sup>st</sup> June 2010

MATRA Limited  
Plot No. 14072, Lumumba Road  
P.O. Box 320193  
LUSAKA

Dear Sir

**Re: FIRE STRYKER FLAME INHIBITOR**

This is to certify that the **Fire Stryker Flame Inhibitor** supplied by MATRA Limited has been assessed and certified by Lusaka City Council Fire Authority in consultation with The Zambia Bureau of Standards as conforming to the requirement of ZS 373.

The Fire Stryker is capable of extinguishing fires of a Class B & C, based in confined spaces. It behaves like a Carbon Dioxide Fire Extinguisher.

LUSAKA CITY COUNCIL FIRE AUTHORITY

  
George Mukupa  
Acting Chief Fire Officer

